

BladderTank Mini

(Part Number INJ-T10M)

10 Gallon Mobile Water Supply

for Philadelphia Scientific® Water Injector Systems™



Storage Battery Systems LLC
N56 W16665 Ridgewood Drive
Menomonee Falls, WI 53051

www.sbsbattery.com

800-554-2243

sbs@sbsbattery.com

PAK089
02/2013



Philadelphia Scientific®
industrial battery innovation

Installation:

Attach the female quick connect coupling to a pressurized water source. **NOTE:** If your water source has very low static water pressure, you may need to use a Booster Pump (INJ-BP) to increase the tank's water capacity. To determine whether you need a Booster Pump, you can either connect up the tank and see how full it gets, or you can use a static pressure gauge to find out your pressure. This table indicates the tank capacity based on pressure.

Water Pressure (PSI)	Tank Capacity (US Gallons)
80	10
70	9.5
60	8
50	6

Maximum input pressure is 100 psi.





Operation Instructions:

Filling the Tank:

The pressure gauge located on the top of the bladder tank shows the pressure inside. If the gauge shows the pressure is less than 30 psi, the tank should be filled. Do not change the factory set air pressure on the top of the Bladder Tank.

Snap the black input hose to the Quick Connect coupling that you have installed on your water source. Turn on the water. Wait until the pressure gauge has stopped moving (usually 5 - 10 minutes), then turn off the tap and disconnect the hose. Store the input hose around the handle and the output hose around the front of the pressure gauge bracket for storage.

Filling the Battery:

<p>1. Connect the Instant Valve Pro™ to the Input Assembly of the Water Injector System installed on the battery.</p>	
<p>2. Squeeze the lever completely to fill the battery. Do Not Partially Squeeze the Lever.</p>	
<p>3. Watch the spinner mounted on the Instant Valve Pro. When it stops spinning, the filling is completed (about 15 seconds, usually).</p>	
<p>4. Release the lever and then disconnect the Instant Valve Pro from the Water Injector System.</p>	



HEALTH AND SAFETY PRECAUTIONS

Batteries contain sulphuric acid, always wear approved protective clothing (gloves, goggles and apron).

