

# INSTALLATION, OPERATING & MAINTENANCE INSTRUCTIONS

*For Vented / Flooded STT Series Batteries used in Stationary Applications*

Commissioning by: .....

Date: .....

Number of cells/blocks: .....

Model #: .....

## SAFETY PRECAUTIONS & WARNINGS

	Familiarize personnel with battery installation, charging and maintenance procedures. Display operating instructions visibly near the battery system. Restrict access to battery area, permitting trained personnel only, to reduce the possibility of injury.
	Wear rubber apron, gloves and safety goggles (or face shield) when handling, installing, or working on batteries. This will help prevent injury due to splashing or spillage of sulfuric acid. Observe all accident prevention rules.
	Prohibit smoking. Keep flames and sparks of all kinds away from the vicinity of storage batteries as liberated or entrapped hydrogen gas in the cells may be exploded, causing injury to personnel and/or damage to cells.
	Wash all acid splashes in eyes or on skin with plenty of clean water and seek immediate medical assistance. Acid splashes on clothing should be washed out with water. Acid on skin or clothing should also be immediately neutralized with a solution of baking soda and water.
	Explosion and fire risk. Avoid short circuits. Never place metal tools on top of cells, since sparks due to shorting across cell terminals may result in an explosion of hydrogen gas in or near the cells. Insulate tool handles to protect against shorting. Prior to making contact with the cell, discharge static electricity by touching a grounded surface.
	Electrolyte is highly corrosive. Promptly neutralize and remove any electrolyte spilled when handling or installing cells. Use a baking soda/water solution (1 lb. per gallon of water) to prevent possible injury to personnel.
	Batteries are extremely heavy. Exercise care when handling batteries. When lifting use appropriate mechanical equipment to safely handle batteries and avoid injury to personnel.
	Dangerous voltage. Whenever possible, when making repairs to charging equipment and/or batteries, interrupt AC & DC circuits to reduce the possibility of injury to personnel and damage to system equipment. This is particularly import with high voltage systems (110 volts and above).
	Recycle and Dispose of Used Batteries Used batteries contain valuable recyclable materials. They must NOT be disposed of with domestic waste. Modes of return and recycling shall conform to the prevailing regulations in operation at the site where the battery system is located. Call SBS for recycling options.

Version: 2013-Dec.1

# TABLE OF CONTENTS

	<b>Page</b>
1.0 Delivery and Storage	1
2.0 Installation	1-3
3.0 Charging	4-5
4.0 Temperature	5
5.0 Electrolyte	5
6.0 Discharging	6
7.0 Special Applications	6
8.0 Maintenance & Testing	6-8
References	9
Battery Log Book	10

## Warranty Note

Any of the following actions will invalidate the warranty:

- Non-adherence to the Installation, Operating and Maintenance Instructions
- Repairs carried out with non-approved spare parts or by non-approved personnel
- Unauthorized interference with the battery
- Mixing different types and/or ages of batteries without obtaining SBS's approval
- Application of additives to the electrolyte
- Operating the batteries above 100°F

Any and all problems or abnormalities must be reported to SBS within 30 days of detection. This includes voltage and or internal resistance readings that are outside the limits in this manual and are not improving when corrective action is applied. Failure to report ANY problems in a timely manner often leads to permanent damage to the battery and the warranty will be void.

# 1.0 DELIVERY AND STORAGE

## Delivery

Unpack the shipment as soon as it is delivered.

Verify that all of the equipment has been delivered and is in good condition. Check quantities against packing slip and accessories list. If there is any damaged or missing product, immediately notify the trucking company as well as SBS.

If necessary, clean all parts before assembling.

## Storage

Fully charged 2V cells have an open circuit voltage of 2.08V +/- .01V; 6V blocks average 6.24V +/- .04V; 12V blocks average 12.48V +/- .06V at 68°F.

Store the batteries in a dry, clean and preferably cool and frost-free location. Do not expose the cells to direct sunlight.

When the batteries are supplied wet and fully charged, storage time is limited. The self discharge of a fully charged STT battery is around 2% per month at 77°F. In order to easily charge the batteries after prolonged storage, it is advised not to store batteries for more than:

- 6 months at 50°F
- 3 months at 68°F
- 2 months at 86°F

An equalizing (refreshing) charge shall be carried out according to charging section 3.0 after this time or if the average open cell voltage drops below 2.04 volts per cell. Alternatively cells can be float charged during storage.

If the batteries are supplied dry charged, the storage time shall not exceed 2 years. For filling, contact sales office for special instructions to fill and commission dry charged batteries.

► **Note:** Failure to observe these conditions may result in reduced capacity and service life as well as voiding the battery warranty.

## Storage of a Battery After Use

Never store a discharged battery. Ensure it is completely charged before storage. Storage times shown above (before use) also apply after use.

# 2.0 INSTALLATION

The electrical protective measures, accommodation and ventilation of the battery installation must be in accordance with the applicable rules and regulations. This includes layout, safety equipment and warning signs required.

## Ventilation

Lead-acid batteries produce hydrogen and oxygen during operation. This is especially true during charging and discharging. These gases result from electrolysis of the water portion of the electrolyte by the charging current. Natural or artificial ventilation should be provided in the battery room, or area, to prevent hydrogen from exceeding a 1% concentration. Concentrations above 4% can result in an explosive mixture, which could be ignited by sparks from adjacent electrical equipment as well as sparks or open flame introduced by personnel. All air moved by ventilation should be exhausted into the outside atmosphere and should not be allowed to re-circulate into other confined areas. Ventilation requirements vary. Contact your local authority for requirements. Use of a hydrogen detector is recommended.

## Location

A battery system should be installed in a clean, cool and dry location. Avoid placing the battery in a warm area or in direct sunlight. Heaters, radiators and steam pipes can cause serious electrolyte temperature variation among cells within a battery system. The layout and contents of a battery room must comply with all local standards and allow easy access to the batteries.

## Handling

Vented lead-acid batteries are normally supplied in a fully charged state and must be unpacked carefully to avoid short circuit between terminals of opposite polarity. The cells are heavy and must be lifted with appropriate equipment. Avoid lifting batteries by the terminal posts. Batteries should be lifted from bottom of jars or with available lifting straps. At all times exercise caution when handling batteries to prevent damage of the plastic containers and covers. The battery containers and covers are delicate and scratches can lead to weakening of the cases. Contact SBS if you are interested in purchasing lifting straps or handling equipment.

## Tools

Use tools with insulated handles. Do not place or drop metal objects onto the battery. Remove rings, wristwatch, and metal articles of clothing which may come into contact with the battery terminals.

## Removal

Before removing old batteries, ensure that all electric loads are switched off (breakers, fuses and switches). This must be carried out by a qualified professional. Batteries must be packaged, shipped and recycled per regulations.


## Rack and Spill Containment Installation

Choose location to install rack and ensure that the area is clean and level. Make sure the rack rails supplied are insulated.

Assemble rack frame according to instructions supplied. If instructions are missing, contact rack supplier

Adjust rack rail spacing to proper width for the cells that are to be installed on the rack.

Set rack frame in final resting place. If mounting to the floor, mark and then drill anchor holes. Install contractor-supplied anchor bolts and tighten.



If an SBS **spill containment system** is supplied the rack will be installed inside the polypropylene spill pans. Polypropylene is acid resistant, extremely strong and can support up to 15,000 lbs. per square inch without degradation of the material. SBS supplies different size spill pans that are butted together in different combinations to form different spill containment system lengths and widths. Flexible connectors are supplied to 'connect' the pans together.

If the rack and spill containment is to be anchored to the floor you will follow the previous rack installation instructions; however, you must also assemble and place the spill containment system under the rack before marking the anchor holes. After the anchor holes are marked, drill through the pans and then drill into the floor. Insert anchor bolts and tighten.

Where needed, caulk hole/bolt with silicon to provide a 100% leak proof spill containment system.

After rack and spill containment system are installed, ensure all bolts are tight and properly torqued.

Optional acid absorbing/neutralizing pillows can be placed in the spill pans after the battery installation is complete.


## Installation of Cells/Batteries

Begin installing the batteries on the lower step or tier for stability and safety reasons. Talcum Powder may be used on the platform surface or rails to ease movement. **DO NOT USE** any other type of lubricant such as Grease or Oil as they may contain mineral spirits which can cause crazing and cracking of the plastic jar material.

Make sure to arrange batteries plumb and level with the correct polarity – see series vs. parallel connection for explanation. Carefully follow the polarity sequence to avoid short circuiting cell groups.


**Series Connection** – batteries are usually installed in series.

Place the batteries on the rack making sure that the positive terminal of one battery is connected to the negative terminal of the next battery and continue in the same fashion. Make sure batteries are aligned properly.



**Figure 1:** These are two 6V batteries in series to produce 12V. You can add more batteries for a higher voltage, i.e. 24, 48, 130 Vdc.

**Parallel Connection** – Batteries may be connected in parallel to give higher current capability. In the case of parallel connected strings, use only batteries of the same capacity, design, and age, with a maximum of four parallel strings. The resistance of the cables in each string must be the same, e.g. same cross section, same length.




**Figure 2:** These are three 12V 100ah batteries in parallel. They produce 12V with 3X the capacity (300ah) of a single battery.

2volt STT should be aligned per the following arrangements or as the intercell connectors dictate.

The STT2V100 - 2V600 cells are placed on the rack with alternating polarities facing forward for proper inter-cell connection alignment.

The STT2V800 - 2V4000 cells are placed on the rack with all of the positive posts pointing to the same side.

Recommended spacing between the cells is noted in Table 1 below, however in non-high rate applications spacing is not required.



**Table 1 – Recommended Spacing**

Battery Type	Recommended Spacing
STT Series (2, 6 or 12 Volt)	1/4 to 1/2 inch

Check that all contact surfaces are clean and corrosion free. If required, clean with brass wire brush.

Apply a thin coat (use sparingly) of No-Ox grease to terminals, on bolt threads, and other exposed metal surfaces. Be careful to avoid contact with the cover and container. **Grease can damage the plastic material. It may contain mineral spirits which can cause crazing and cracking of the plastic jar material.**

Tighten the terminal screws with an insulated torque wrench in accordance with Table 2 below.

Fit inter-step, row, or tier connector (jumper) cables – observe the same torque values noted in Table 2.

A loose connection can make adjusting the charger difficult, create erratic performance, and lead to possible damage to the battery and/or even personal injury.

After all bolts are properly torqued, fit any insulating covers/boots supplied for protection against inadvertent contact.

Remove transport plugs and replace with the permanent flip-top flame arrestor vent caps supplied.

Number the cells for maintenance purposes, starting from the positive end terminal to the negative end terminal.

**Table 2 – Torque Loadings for Terminal Screws**

Battery Type	Terminal Bolt	Maximum Torque ± .05%		
		Inch Pounds	Foot Pounds	Nm
STT 6 & 12 Volt	M8	132	11	15
STT 2 Volt*	M10	180* - 221	15* - 18	20* - 25

\*Recommended for STT2V100-150 batteries

### Charger Connection

Before charger is connected, make sure the cells are clean and double check all connections for correct torque (Table 2) and polarity. Ensure all battery to battery, battery to terminal connections, as well as inter-level and load connections have appropriate internal resistance values.

Measure the total voltage of the battery string at the end battery terminals. The voltage should be equal to the number of cells (batteries) times the voltage of one of the cells (batteries).

**Example:** 60 cells times a standard open circuit voltage of 2.08V = 124.8Vdc.

Finally, with the charger switched off, the battery fuse removed, and the load disconnected, connect the battery to the DC power supply. Ensure that the polarity is correct – positive terminal of the battery to the positive terminal of the charger.

Switch on the charger (per charger instructions) and adjust the float and equalize voltages as needed. Charge according to charging instructions 3.0.

► **Note:** After the Initial Charge, record all of the data specified under the Required Periodic Inspection and Maintenance Activities Annual Battery System Checks (including monthly and quarterly data), and save the data. Documentation of maintenance activities will be required in case of warranty claim or problems with the battery system.

## 3.0 CHARGING

### Charging Current

Limitation of the charging current is not required under floating condition. During the initial or an equalizing charge, the current should be limited to 30% of the Ah rating of the battery.

**Example:** STT2V100 = 110Ah, maximum charge current should be  $.30 \times 110 = 33\text{Amps}$ .

After reaching the gassing voltage of 2.40Vpc, a current limit of 2.5-5amps per 100Ah is recommended.

### Ripple Current

In the standby operation mode, the effective value of the AC ripple current must not exceed 5A per 100Ah @ 8Hr. Otherwise, reduced operational life as well as increased maintenance (watering) should be expected. Charging current should be filtered so that the battery system will have maximum life and minimum maintenance during its life. You should never operate an unfiltered charger without a known good battery connected to the DC bus.

### Initial Charge (Commissioning Charge)

Before initial charge, all batteries must be inspected for physical/mechanical damage.

The electrolyte levels should be topped off with distilled water AFTER the initial charge unless the electrolyte level before the initial charge is within  $\frac{1}{2}$ " of the tops of the plates.

Charge at a voltage of 2.40Vpc for 24-72 hours. The fully-charged condition has been achieved when, for a period of two hours, the cell voltages do not continue to increase and the charging current does not continue to decrease.

A fully charged STT cell will have a temperature-corrected specific gravity of 1.240 (tolerance: +/- 0.01) assuming the electrolyte levels are at the 'max' line — see Table 3.

Upon completion of the initial charge place the batteries on float charge.

Batteries are shipped from SBS at approximately 90-100% capacity and will attain 100% capacity after 1-6 months on float charge.

### Record Initial Reference Values

After the initial charging of the battery, measure all of the cell internal resistance values and voltages using a battery internal resistance tester. Ensure all battery to battery, battery to terminal connections, as well as inter-tier and load connections have appropriate resistances. Record all of these initial values for comparison over the life of the battery system. In addition, the following data should be documented for initial charging records:

- Date and time of the completion of the Initial Charge on the battery system
- Float Voltage of the DC output of the charger as measured on the main (+) and (-) terminals of the battery.
- Float Current of the DC output of the charger measured on the cable(s) to the positive post of the battery.
- Float AC ripple voltage and current as measured on the main (+) and (-) terminals of the battery.
- Battery temperature (at negative post) and ambient temperature.

### Float Charge

**Batteries must be maintained on float charge and should be fully recharged within 24 hours of any discharge.**

The recommended float charge voltage is 2.23Vpc at 77°F. Floating the batteries above 2.23Vpc may lead to overcharging; additional watering be required as well as a shorter service life. Floating the batteries under 2.23Vpc without a regular equalize charge may lead to reduced capacity, sulfation build-up and premature failure. For these reasons, we recommend 2.23Vpc @ 77°F, whenever possible.

The system float voltage should equal: (# of cells in system) x 2.23Vpc = System Float Voltage.

Float voltage should not vary by more than +/-1%. Should the float voltage of any cell vary by +/-0.02Vpc apply an equalize charge and contact your sales office should this not correct the problem.

### Float Charge Adjustment

The float charge voltage will need to be adjusted if the average operating temperature is above 86°F or below 50°F.

SBS does sell chargers that automatically compensate the float voltage with an increase or decrease in temperature; however, if you do not have temperature compensation on your charger you will have to make the following adjustments to assure you are not over or under charging the system: If the average battery temperature exceeds 86°F, the float charge voltage shall be reduced by  $(AT - 86) \times .003\text{Vpc}$  (but not less than 2.18Vpc). If the average battery temperature is lower than 50°F, the float voltage shall be increased by  $(50 - AT) \times .003\text{Vpc}$ . AT=the average operating temperature.

**Example:** AT= 92°F:  $(92-86) \times .003 = \text{reduce Vpc by } .018$ . A 60 cell system with a standard float voltage of 133.8Vdc (2.23Vpc) should be floated at 132.72Vdc if the operating temperature is 92°F.

## Equalizing Charge (AKA Refreshing Charge or Boost Charge)

- ▶ **Note:** Because the permissible system voltage level may be exceeded when equalize charging at increased voltages, suitable measures should be taken to protect the load circuits (e.g. charging off-line).
- ▶ **Note:** Lead-selenium batteries do not necessarily require a periodic equalize charge for the system to deliver 100% capacity. A quarterly 24-72 hour equalize charge on the system will help ensure that the voltage and specific gravity readings of the batteries stay within tolerances without a significant effect on watering intervals.
- ▶ **Note:** Leaving batteries on equalization charge for long periods of time may result in: voided warranty, seriously overcharging the battery causing loss of electrolyte (dry out) and shortened system life.

### When should an equalize charge be applied?

- Quarterly – not necessary but this will help keep cell voltages in line and will assure 100% capacity
- When individual cells fall below 2.21Vpc or when block voltage falls below 13.26Vdc for 12V blocks or 6.63Vdc for 6V blocks
- When electrolyte levels have been adjusted – water added
- When the majority of S.G. readings (corrected to 77°F) are under 1.235 S.G.
- After a deep discharge, or after an inadequate recharging, an equalizing charge can help recharge the system quicker

Charge at a voltage of 2.33-2.40Vpc for 24-72 hours. Current should be limited to 30% of the amp hour rating of the battery. The actual time needed to equalize depends on the initial state of charge of the battery system and the voltage and current applied. To ensure the cells are not overcharged, electrolyte S.G. should be checked on 3-4 pilot cells during the equalize charge. The fully charged condition has been achieved when, for a period of two hours, the cell voltages or SG readings do not continue to increase and the charging current does not continue to decrease.

If the maximum temperature of 113°F is exceeded, charging must be terminated or continued at a reduced current or temporarily switched to float charging.

Upon completion of the equalize charge place the batteries back on float charge.

***If there are still voltage and/or specific gravity discrepancies after an equalize charge is carried out contact SBS.***

## Recharge

After a discharge, the battery can be recharged at the operating voltage (float voltage) or to reduce the charging time the recharging can be carried out per the equalizing charge instructions. The recharging times vary depending on the charging procedure and on the charging current available. Recharge 1.2 times the discharged capacity.

## 4.0 TEMPERATURE

Higher temperatures reduce the operational life. Lower temperatures reduce the available capacity.

The permissible operating temperature range is 5°F to 130°F. The recommended operating temperature range is 68°F to 77°F. This will maximize life and minimize maintenance. All technical data relates to a rated temperature of 77°F (25°C).

If the battery operating temperature is different from 77°F, a correcting factor is to be applied to capacity value taking into account discharge time. **(Reference IEEE-450-2010)**

## 5.0 ELECTROLYTE

Electrolyte is a diluted sulfuric acid. The nominal S.G. of the electrolyte at 77°F is 1.240. The maximum deviation is +/- .01g/cm<sup>3</sup>. Higher temperatures will decrease electrolyte density, while lower temperatures increase electrolyte density. The correction factor is .001 for each 3°F. For each 3°F over 77°F, add .001 to the S.G. reading. For each 3°F below 77°F, subtract .001 from the S.G. reading.

**Table 3 – Approximate Electrolyte Values According to Electrolyte Level**

Type	Approximate SG Values		
	'Min' line	Middle	'Max' line
STT Series	1.26	1.25	1.24

## 6.0 DISCHARGING – End of Discharge Voltage Limits

The battery must not be discharged more than the capacity specified in the performance data tables. Deeper discharges may damage the battery and shorten its operational life. A low voltage disconnect is recommended to prevent deep discharge.

As a general rule, the end of discharge voltage shall be limited to the values listed below:

**Table 4 – Discharge Voltage**

Discharge Time	End Voltage
5 min. < t < 59 min.	1.70Vpc
1 hr. < t < 8 hrs.	1.75Vpc
8 hr. < t < 24+ hrs.	1.80Vpc

Individual cell voltages should ideally not fall below end voltage per cell by more than 0.2Vpc. A low voltage disconnect is recommended to prevent deep discharge.

### Discharged Cells

Batteries must not be left in a discharged condition. They must be immediately returned to recharge mode. Failure to observe these conditions may result in greatly reduced service life. See section 3.0 for charging instructions.

► **Note:** Each deep discharge is abusive and could affect the life expectancy of the battery.

## 7.0 SPECIAL APPLICATIONS

Whenever the batteries are to be used for special applications (non floating type applications) such as repeated cycling or under extreme ambient conditions, please contact your sales office. Different instructions may apply. In addition, the battery may have a shorter operational life.

## 8.0 MAINTENANCE & TESTING

### Water Topping

Under ideal operating conditions, lead-selenium flooded batteries should require watering every 1 to 3 years. Watering intervals depend on temperature, charging rates, and the number and depth of discharges.

► **Note: DO NOT ADD WATER TO A BATTERY WHICH ISN'T FULLY CHARGED.** This is especially important as the battery is being commissioned.

Top up the electrolyte level to the nominal level, but without exceeding the 'max' line. Topping over max line when combined with an equalize/boost charge can lead to electrolyte spewing from the vent caps or a broken jar to cover seal.

**Use ONLY de-mineralized or distilled water (purity grade: maximum conductivity 10 µS/cm).**

On float charge, the homogenization will eventually occur and an equalize charge is not necessary.

If preferred after topping off the water level, an equalize charge up to 24 hours can be applied to help reduce the time for homogenization of the electrolyte density.

### Cleaning

Keep containers and lids dry and free from dust. Cleaning must be undertaken with a damp cotton cloth without man-made fibers or addition of cleaning agents. Do not use feather dusters or dry cloths. This could cause static discharge which can lead to an explosion hazard

### Ceramic Plugs

Wash ceramic plugs, if soiled (about every 2-5 years), in clean water and dry them thoroughly before putting them back on the battery.

## Capacity/Discharge Testing

Capacity tests should be carried out in accordance with IEEE-450-2010. Discharge tests should be performed between 65°F and 90°F.

### Pretest requirements

- An equalize charge should be completed. 72 hours at 2.40Vpc is recommended by SBS.
- A float charge of no less than 72 hours should follow the equalize charge up to the start of the test. All battery voltages should be within tolerances noted in charging section 3.0. If any batteries have a voltage outside of the allowable float charge range SBS should be contacted prior to the test starting.

### Test length

SBS recommends discharge times of 1 to 8 hours to an end cell voltage of 1.75Vpc.

### Discharge Rate

Performance data is available at [www.sbsbattery.com](http://www.sbsbattery.com) or can be supplied by contacting SBS.

### Information to Record Before and During Test

- Record the overall float voltage and current of the string just before the start of the test (with charger on).
- Record the float voltage at the battery terminals just before the start of the test (with charger on).
- Record the float voltage of each cell/block just before the start of the test (with charger on).
- Record the electrolyte temperature of 10% or more cells to establish an average temperature (every 6<sup>th</sup> cell).
- At regular time intervals during the test, measure Total Vdc, Amps DC and Individual cell voltages of all batteries / cells.
- As the test nears its end, it may be necessary to take readings more frequently to monitor cells that are approaching low voltage limits.

### What to do if a Cells Voltage drops below the Specified End Cell Voltage Prematurely – Per IEEE450

- Do not interrupt test until an individual cell voltage is less than 1 volt.
- If one or more cells are less than 1 volt, however the test time is 90%+ completed, continue the test until the specified end system voltage is reached.
- If earlier in the test, an individual cell is less than 1 volt but the total end system voltage has not yet been reached, the test should be stopped and the weak cell should be disconnected from the battery string and bypassed with a jumper of adequate conductor ampacity. The new minimum terminal voltage should be determined based on the remaining cells. The test should then be continued in order to determine the capacity of the remaining cells. The time required to disconnect the cell, install the jumper, and restart the test shall not exceed 6 minutes. This “downtime” shall not be included in the test discharge period (i.e., the capacity determination shall be based on the actual test time). No more than one “downtime” period should be allowed when a battery is being tested.

### Temperatures effect on a Capacity/Discharge Test

If the operating temperature of the system is above or below 77°F, a correction factor will need to be applied to either the test results\* or to the current applied to determine the true capacity of the system. (Reference IEEE-450-2010)

#### \*Time Adjusted Method for Calculating System Capacity – Recommended by SBS

When using this method, no correction of any type is required prior to the performance of the test. The system’s capacity is calculated after the completion of the test using the published performance data at 77°F. This method is recommended for test over 1 hour.

$$\text{To calculate the \% capacity of your system } C = \frac{T_a}{T_s \times K_t} \times 100$$

- C = % capacity at 77°F
- T<sub>a</sub> = the actual time (in minutes) of the test to specified end cell voltage
- T<sub>s</sub> = the rated time (in minutes) of the test to specified end cell voltage
- K<sub>t</sub> = the time correction factor in Table 5

**Table 5 –Recommended Temperature-Correction Factor (Kt)**

°F	65	67	69	70	71	73	75	77	79	80	81	83	85	87	89	90
Kt	0.920	0.935	0.948	0.955	0.960	0.975	0.985	1.000	1.007	1.011	1.017	1.030	1.040	1.050	1.060	1.065

**Example:** A STT2V200 battery is rated to deliver 38Amps for 5 hours (300 minutes) to 1.75Vdc at 77. The system was 65°F, was discharged at 38Amps and the systems end cell voltage was reached at 4 hours and 25 minutes (265 minutes).

$$C = \frac{265}{300 \times .92} \times 100 = \text{System has 96\% Capacity}$$

# REQUIRED PERIODIC INSPECTION AND MAINTENANCE ACTIVITIES

Keep a logbook in which the measured values as well as power cuts, discharge tests, equalize charges, water topping up dates, storage times and general conditions can be noted. If a problem or warranty situation does come up this information is necessary in determining the course of action.

To obtain the full capacity and service life from your SBS stationary battery system, the performance of complete and timely periodic maintenance is essential. Temperature extremes, improper electrolyte levels, charging voltage and specific gravity imbalance are a few of the items which can have a negative effect on the system.

Routine inspection, charger/rectifier checks, and pilot cell checks should be performed monthly. More detailed inspection of the battery is required on a quarterly and annual schedule.

## GENERAL BATTERY ROOM AND EQUIPMENT INSPECTION – perform the following checks whenever in the battery room:

- The battery room is clean, dry, and clear of debris and within a 68-77°F temperature range.
- The battery room ventilation system is operating.
- Battery room and personal safety equipment is available and operational.
- Battery cleaning and acid neutralization supplies are available on site.

## MONTHLY BATTERY SYSTEM CHECKS – record in a log book the following:

- Record the battery system float charging voltage: **Measure voltage at battery terminals.** It should equal 2.23V x number of cells. If a deviation in voltage greater than +/- 1% occurs, the charger must be adjusted or checked for proper operation.
- Record each pilot cell charging voltage: The pilot cell charging voltage should be: 2.23V +/- .02V for 2V cells, 6.69V +/- .04V for 6V blocks or 13.38V +/- .06V for 12V blocks.
- Record the pilot cell electrolyte temperatures: The normal range is between 68-77°F, and should have a variance no greater than 5°F between individual cells.
- Record the pilot cell specific gravities, corrected for temperature: It should read 1.240, within .005 of previous two normal readings, and within a range of .010 of the pilot cells' average specific gravity. It is important to take specific gravity readings prior to adding water to the cells.
- Electrolyte levels of all cells must be between the high and low level marks on the cells: If water is added, record this event.
- All cells have clean vent caps installed.
- Visually inspect each cell noting any changes or abnormalities. If anything odd is noticed, record it and call sales office immediately to determine proper action. Changes you should look for may be, but are not limited to the following: discoloration, cracks, corrosion, and growth inside or outside of container. Any noticeable sign may be a sign of trouble.
- All cells and racks are clean, dry and free of any leaks, spilled electrolyte and corrosion.
- Record room temperature.

► **Note:** Individual cell charging voltage and specific gravity measurements are most accurate if 72 hours or more have elapsed since the system was discharged or equalized. Specific gravity readings taken within 6 weeks of water additions may not be accurate.

## QUARTERLY BATTERY SYSTEM CHECKS – record in a log book the following:

In addition to the monthly inspection the following checks should be completed quarterly.

- Record the charging voltage of each cell or multi-cell block in the battery system.
- Record the Internal Resistance of each cell or multi-cell block.
- Review the general condition or change in condition of the cells, racks, cables and connectors.
- Record temperature of electrolyte in each pilot cell.
- Record the specific gravity of each cell in the battery-corrected for temperature.

## ANNUAL BATTERY SYSTEM CHECKS – record in a log book the following:

In addition to the quarterly and monthly inspection checks, perform the following checks annually.

- Check torque of all connections (batteries and racks).

## CAPACITY TESTING CHECKS – record in a log book the following:

In addition to all of the normal maintenance checks, a periodic capacity test of the battery system should be performed to verify the ability of the battery system to perform to specifications. SBS suggests conducting a capacity test (2) two years after installation and then every (5) five years. When the capacity of the system falls below 90% a capacity test should be performed annually, every (1) year.

## **SUGGESTED REFERENCES**

### **IEEE-484-2002**

Recommended Practice for Installation Design and Installation of Vented Lead Acid Batteries for Stationary Applications

### **IEEE-450-2010**

Recommended Practice for Maintenance, Testing and Replacement of Vented Lead Acid Batteries for Stationary Applications

### **IEEE-485-2010**

Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications

### **IEEE-1657-2009**

Recommended Practice for Personnel Qualifications for Installation and Maintenance of Stationary Batteries

If you have any questions or concerns contact SBS Stationary Technical Support.

E-mail: [techsupport@sbsbattery.com](mailto:techsupport@sbsbattery.com)

Phone: 1-800-554-2243

**Early detection and corrections of problems  
can help prevent permanent damage to your  
battery system!**



## BATTERY LOG BOOK

LOCATION / SITE NAME:	DATE:	TESTED BY:
DATE SYSTEM INSTALLED:	CHARGER P/N	
BATTERY P/N	SPECIFIC GRAVITY:	CHARGER VOLTAGE : _____Vdc
BATTERY VOLTAGE:	# OF CELLS:	CHARGER CURRENT: _____Amps
ELECTROLYTE LEVELS: ____'Max' ____'Middle' ____'Min'		AMBIENT ROOM TEMP:

Cell #	Voltage	Specific Gravity	S.G. Temp.	Cell #	Voltage	Specific Gravity	S.G. Temp.	Cell #	Voltage	Specific Gravity	S.G. Temp.	Cell #	Voltage	Specific Gravity	S.G. Temp.
1				16				31				46			
2				17				32				47			
3				18				33				48			
4				19				34				49			
5				20				35				50			
6				21				36				51			
7				22				37				52			
8				23				38				53			
9				24				39				54			
10				25				40				55			
11				26				41				56			
12				27				42				57			
13				28				43				58			
14				29				44				59			
15				30				45				60			

Battery Room Condition:
Battery System Condition:
Did you Water the System: ____YES ____NO      If so how much water was added? _____
Any other Comments:

Contact SBS immediately if you find anything that doesn't look right or if you have any questions.  
**Storage Battery Systems - N56 W16665 Ridgewood Drive – Menomonee Falls, WI 53051**  
 Phone: (262) 703-5800 - Toll Free: (800) 554-2243 - Fax: (262) 703-3073  
 Website: [www.sbsbattery.com](http://www.sbsbattery.com)